

গণপ্রজাতন্ত্রী বাংলাদেশ সরকার

শ্রম ও কর্মসংস্থান মন্ত্রণালয় কলকারখানা ও প্রতিষ্ঠান পরিদর্শন অধিদপ্তর

"সুস্থ শ্রমিক, শোতন কর্মপরিবেশ; াড়ে জুলবে স্মার্ট বাংলাদেশ"

ক্যাপ পর্ববেষ্ফণের তখ্য

কারখানার নাম	কনভিন্স এ্যাপারেলস লিঃ
ঠিকানা	Plot # 68-71, Block-Section # 2, Rupnagar, Mirpur, Dhaka .
কারখানার কোড	DHK 136
কালার কোড	

মূল্যামনের ধরণ: কাঠামোগত মূল্যামন	পর্ববেষ্ফণের তারিখ: ৩০–০১–২০২৩
১. পর্যবেষ্ণণ	

পরিদর্শন Cursory calculations indicate high punching shear stress in the flat plate slabs of 1st, 2nd and 5th পর্ববেষ্ণন floor. Flat plate thickness is 6.5...
ক্যাপ
আইটেম
ক্যাটাগরি

কাৰ্যক্ৰম	Verify in–situ concrete stresses either by 100mm dia. cores or existing cylinder strength data Cores to be taken from 4 different areas of slab at different level.
সুপারিশের ভখ্যসূত্র	
কার্য্থানার কার্যক্রম	We have engaged a consulting firm .
<u> অগ্রা</u> খিকার	প্রবোজ্য ন্য
হুডান্ড শমশ্রসীমা	07-09-5078
ণংশোধিত নমশ্রসীমা	07-07-7940
মগ্রগতির মবস্থা	সংশোধিত
মন্ত ব্য	01.10.2020: They have got the approval of DEA report from DIFE, but they did not able to show any approved copy during inspection time. One follow up visit was held on the factory and they got some mismatch. The management suggested by engineering team to do the re of the work but the factory didn't do any work due to corona. 13.01.2021: This issue covered by DEA. They have got the approval of DEA report from DIFE, but they did not able to show any approved copy during inspection time. 06/06/2021: All revised documents including DEA report with core test result is re–submitted to DIFE on 07–03–21. Now they are waiting for approval. 29.08.2021: All revised documents including DEA report with core test result is re–submitted to DIFE on 07–03–21. They got the approval for the Business Certificate from the task Force Number of 157 on May–30–2021. 10/08/2022: The DEA report has received approval from DIFE and also received 'Certificate of Business as Usual'. 30–01–2023: Completed.

x x x x

১.২. কাৰ্যক্ৰম Results of flat plate review to be input to Loading Plan. Continue to implement load কাৰ্যক্ৰম management plan. সুপারিশের ভ৾খ্যসূত্র কার্থানার Do কাৰ্যক্ৰম অগ্রাধিকার চুডান্ড 57-07-5070 সংশোধিত 02-05-5590 সমশ্বসীমা অগ্রগতির সংশোধিত অবস্থা 01.10.2020 visit observation: They have got approval of DEA report from DIFE. But the factory management didn't do any work due to corona. 13.01.2021: This issue covered by DEA. They have got the approval of DEA report from DIFE, but they did not able to show any approved copy during inspection time. 06/06/2021: All revised documents including DEA report with মন্তব্য core test result is re-submitted to DIFE on 07-03-21. Now they are waiting for approval. 29.08.2021: All revised documents including DEA report with core test result is re-submitted to DIFE on 07-03-21. They got the approval for the Business Certificate from the task Force Number of 157 on May-30-2021. 10/08/2022: The DEA report has received approval from DIFE and also received 'Certificate of Business as Usual'. 30-01-2023: Completed. সংখুক্তিসমূহ (২)

পর্বিদর্শন There is an additional roof truss steel shed on roof which covers 40% of the roof top. No পর্ববেষ্ণণ design documents of the shed have been found. ক্যাপ আইটেম্

ক্যাটাপরি			
.১. কাৰ্যক্ৰম			
. 3. 위기⊅역 			
কাৰ্যক্ৰম	Building engineer to check the capacity and stability of the lightweight roofs and make any necessary alterations.		
সুপারিশের তথ্যসূত্র			
কারখানার কার্যক্রম	Do		
অগ্রাধিকার	প্রবোজ্য নর		
চুডান্ড সমশ্রসীমা	0~-0~-く0~		
সংশোধিত সময়সীমা	02-02-229		
অগ্রগতির অবস্থা	সংশোধিত		
মন্তব্য	01.10.2020: There is an additional roof truss steel shed on roof but the assigned consultant firm didn! t show this structure in architectural drawing. 13.01.2021: No drawing found for roof shed. 06/06/2021: According to the Taskforce review the factory is advised to demolish the shed building of roof. Now the factory has been continuing its demolition work. 29.08.2021: According to the Taskforce review the factory is advised to demolish the shed building of roof. Now the factory has been continuing its demolition work. 10/08/2022: Roof steel shed has found demolish during inspection date. 30-01-2023: Completed.		
সংযুক্তি × ×	সমূহ (৬) × × × ×		

:.২. কাৰ্যক্ৰম	
কাৰ্শক্ৰম	Carry out upgrade measures required as part of the design checks. Prepare as built structural drawings for additional structure
সুপারিশের তথ্যসূত্র	
কার্থানার কার্যক্রম	Do
অগ্রাধিকার	
চূডান্ড সমশ্রসীমা	57-07-507d
সংশোধিত সমশ্বসীমা	07-07-7940
অগ্রগতির অবস্থা	সংশোধিত
মন্তব্য	01.10.2020 visit observation: No upgrade measure showing the Structural design drawing. 13.01.2021: No structural drawing found for roof shed. 06/06/2021: According to the Taskforce review the factory is advised to demolish the shed building of roof. Now the factory has been continuing its demolition work. 29.08.2021: According to the Taskforce review the factory is advised to demolish the shed building of roof. Now the factory has been continuing its demolition work. 10/08/2022: Roof steel shed has found demolish during inspection date. 30-01-2023: Completed.

<u>৩. পর্যবেক্ষণ</u> পরিদর্শন Dampness was observed on the walls and ceiling of basement, 1st, 5th and 6th floor. পর্যবেক্ষণ The possible cause of dampness is leakage of pipes. ক্যাপ আইটেম ক্যাড়াগরি

৪. পর্যবেষ্ফণ

পরিদর্শন পর্শবেষ্ফণ	Exposed rebar were observed at roof top.
ক্যাপ আইটেম ক্যাটাগরি	İ

৪.১. কাৰ্যক্ৰম

কাৰ্যক্ৰম	Provide protective coating to cover the exposed rebar from corrosion.
সুপারিশের	
ভিখ্যসূত্র	
কারখানার	Do
কাৰ্যক্ৰম	
অগ্রাধিকার	প্রবোজ্য নয়
চুডান্ড সমশ্বসীমা	₹%-0%-₹0%9
সংশোধিত সময়সীমা	02-02-229
অগ্রগতির অবস্থা	সংশোধিত
মন্তব্য	01.10.2020 visit observation: They have Provided protective cover to the exposed rebar in roof top. 13.01.2021: Exposed rebar was covered with brick wall. 06/09/2021: There is no exposed rebar is found in roof floor. 29.08.2021: There is no exposed rebar is found in roof floor. 10/08/2022: No Exposed rebar were observed at roof top during inspection date. 30-01-2023: Completed.

সংখুক্তিসমূহ (8)