

গণপ্রজাতন্ত্রী বাংলাদেশ সরকার

শ্রম ও কর্মসংস্থান মন্ত্রণাল্য কলকারখানা ও প্রতিষ্ঠান পরিদর্শন অধিদপ্তর

"সুস্থ শ্রমিক, শোতন কর্মপরিবেশ; াড়ে জুলবে স্মার্ট বাংলাদেশ"

ক্যাপ পর্ববেষ্ফণের তথ্য

কারখানার নাম	ইউমে নিটিং (বিডি) লিমিটেড
ঠিকানা	Charkidirpur, Pashchim gumdondhi, Boalkhali, Chattogram
কারখানার কোড	CHT191
কালার কোড	

	: কাঠামোগত মুল্যারন প্রবিশ্ব পার্বথ: ২৩–০২–২০
পর্ববেষ্কণ	
ারিদর্শন 🚶	
Ab	pproval Drawings
চ্যাপ মাইটেম	
শাখভেশ চ্যাটাগরি	
P) 9 11	
১. কাৰ্যক্ৰম	
কাৰ্যক্ৰম	As-built architectural and structural drawings of the building to be prepared and submitted for approval by appropriate authority. As part of this process the building engineer will be required to make a number of checks on the inconsistencies between the structural design and the as-built construction.
সুপারিশের তখ্যসূত্র	
কার্থানার কার্যক্রম	We will engage a building engineer to prepare as-built architectural and structural drawings for the building and will submit for approval by appropriate authority and as part of this process the building engineer will make a number of checks on the as-built construction.
<u>অগ্রা</u> খিকার	প্রযোগ্য নর
চুডান্ত সময়সীমা	20-20-2029
সংশোধিত সমশ্বসীমা	07-07-7940
অগ্রগতির অবস্থা	সংশোধিত
মন্তব্য	On 19/12/2018: Waiting for DEA approval On 26/02/2019: Same as before On 01/10/2020: DEA Approved. On 06/01/2021: Design Drawing and DEA Approved. 01.09.2021: This issue is solved. 24-05-2022 (CCVV): Few mismatch in as-built Structural drawing have been found in column and beam sizes. As-built drawing and DEA report must be updated and submitted to DIFE. 23-02-2023 (CCVV): During the day of CCVV, it was found that factory have corrected all the necessary items related to as-built documents & approval documents have been found during the day of visit.
সংযুক্তি × ×	मभूर (२)

পরিদর্শন পর্শবেষ্ <u>ষ</u> ণ	Non-Engineered Stair
ক্যাপ আইটেম ক্যাটাগরি	[

২.১. কাৰ্যক্ৰম

কাৰ্শক্ৰম	The connection of steel stair needs to be checked by building engineer and the bracing system is required to ensure the stability of the structure. Carry out any remedial actions as directed by the Building Engineer for steel stairs.
সুপারিশের তখ্যসূত্র	
কারখানার কার্যক্রম	remedial actions as directed by the Building Engineer for steel stairs.
অগ্রাধিকার	প্রযোগ্য নয়
চুডান্ড সমর্মীমা	20-20-2029
সংশোধিত সময়সীমা	07-07-7940
অগ্রগতির অবস্থা	চলমাল
মন্তব্য	On 30/10/2018: Submitted with DEA. After approval they will carry out the remedial work (if Any) On 19/12/2018: Same as before On 26/02/2019: Same as before On 06/01/2021: Still not started Retrofitting work of Steel Stair. 01.09.2021: Still not start retrofitting work. 24-05-2022 (CCVV): Factory did not started retrofitting work of Steel Stair. 23-02-2023 (CCVV): Retrofitting of stair have been done. The Issue have been resolved.
यःशक्ति	<u> </u>